



NOTES:

1. SERVICE VALVE TO BE LEFT IN THE OPEN POSITION.
2. UNLESS OTHERWISE NOTED ALL 1 1/4" DIAMETER PVC PIPE SHALL HAVE SOLVENT CEMENT JOINTS AND HDPE WILL HAVE BUTT FUSED JOINTS.
3. FITTINGS SHALL BE BLOCKED OR ANCHORED IN ACCORDANCE WITH DETAILS PS/1.4, 1.41 & 1.42.
4. BALL VALVE SHALL HAVE A 2" BY .5" OPERATING NUT FOR USE WITH A CURB KEY.

WASHINGTON
SUBURBAN
SANITARY
COMMISSION

APPROVED: 8/18/16

Chief Engineer

STANDARD DETAIL
PRESSURE SHC WITH
SERVICE VALVE
ASSEMBLY

PS
1.1