



**NOTES:**

1. ALL JOINTS SHOWN SHALL BE SOLVENT CEMENT UNLESS OTHERWISE NOTED.
2. FOR OTHER MANHOLE DETAILS, SEE DETAIL S/1.2.
3. ALLOW SUFFICIENT SPACE FOR UNSCREWING UNION.
4. FOR HDPE PIPE, PROVIDE TRANSITION FITTING AT CONNECTION TO BALL VALVE.

WASHINGTON  
SUBURBAN  
SANITARY  
COMMISSION

APPROVED: 8/18/16  
  
Chief Engineer

STANDARD DETAIL  
**FLUSHING  
CONNECTION  
2-1/2" THROUGH 4"**

PS  
1.3