


PIPE SIZE	M	N	P
1 1/4"	6"	6"	8"
1 1/2"	6"	6"	8"
2"	6"	8"	8"
2 1/2"	8"	8"	10"
3"	12"	18"	12"
4"	12"	18"	12"

NOTES:

1. CARRY ALL BEARING SURFACES TO UNDISTURBED EARTH OR FIRM SUBGRADE.
2. BUTTRESS SIZED FOR 150 psi.
3. NOMINAL THICKNESS OF ALL BOARDS IS 2".
4. ALL BOARDS TO BE PRESSURE TREATED YELLOW PINE.

WASHINGTON
SUBURBAN
SANITARY
COMMISSION

APPROVED: 8/18/16

Chief Engineer

STANDARD DETAIL
PRESSURE SEWER AND
HOUSE CONNECTION
BLOCKING DETAILS
FOR CAPS AND PLUGS

PS
1.41