



WASHINGTON SUBURBAN SANITARY COMMISSION

SANITARY SEWER OVERFLOW WRITTEN REPORT

3605863-118-2026

MDE OFFICIAL CONTACTED: JORDAN RHOOMS

DATA CALLED IN BY: BRANDON T MCCREA

DATE: 07/04/2026 AT 11:35AM

WORK ORDER(S): 3605863 3605862

EST DATE AND TIME SSO BEGAN: 07/04/2026 07:49AM DURATION: 1.85 HRS

DATE AND TIME SSO ENDED: 07/04/2026 09:40AM

SOURCE-OVERFLOWING MH MH05121015 WATER BODY AFFECTED-ROCK CREEK

CLOSEST STREET ADDRESS: 12801 BUSHEY DR 20906

COUNTY/PAGE/GRID: M 5165 H10 TOWN/CITY: SILVER SPRING

CAUSE: WIPES

EST OVERFLOW VOLUME: 222 GAL

UPON ARRIVAL, THE CREW FOUND MANHOLE 015U OVERFLOWING ONTO THE PAVEMENT AND INTO A TRIBUTARY OF TURKEY BRANCH CREEK. THE CREW JETTED FROM MANHOLE 014U TO 015U A TOTAL OF 270', HITTING AND RELIEVING WIPES AT 260', TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DRY WEATHER

PUBLIC ACCESS

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

FLUSHED BACK INTO MANHOLE

NOTIFICATIONS MADE:

MD DEPARTMENT OF ENVIRONMENT
MONTGOMERY CO MUNICIPALITIES

DEP-MONTGOMERY COUNTY

SIGNS POSTED: 5 POST DATE: 07/04/2026