



WASHINGTON SUBURBAN SANITARY COMMISSION

SANITARY SEWER OVERFLOW WRITTEN REPORT

3606366-118-2026

MDE OFFICIAL CONTACTED: CHRISTIE WAGNER

DATA CALLED IN BY: DON O DARKO

DATE: 07/07/2026 AT 04:15PM

WORK ORDER(S): 3606366 3606349

EST DATE AND TIME SSO BEGAN: 07/07/2026 02:50PM DURATION: 1.17 HRS

DATE AND TIME SSO ENDED: 07/07/2026 04:00PM

SOURCE-OVERFLOWING MH MH18009011 WATER BODY AFFECTED-OXON RUN

CLOSEST STREET ADDRESS: 5001 BROOKHAVEN CT 20745

COUNTY/PAGE/GRID: P 5649 C09 TOWN/CITY: OXON HILL

CAUSE: ROOTS EST OVERFLOW VOLUME: 140 GAL

UPON ARRIVAL, THE CREW FOUND MANHOLE 011M OVERFLOWING, APPROXIMATELY 2GPM, ONTO THE GRASSY AREA AROUND THE MANHOLE AND INTO A NEARBY UNKNOWN WATERWAY THAT OUT FALLS INTO THE OXON RUN BASIN. THE CREW JETTED FROM MANHOLE 011M TO 010M, A TOTAL OF 287FT, AND RELIEVED A ROOTS OBSTRUCTION AT 219FT, TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DRY WEATHER

DISCOLORATION

NOTICEABLE ODOR

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

LIME

RAKED AREA

VISIBLE SOLIDS REMOVED

THE CREW SPREAD LIME IN THE GRASSY AREA AROUND THE MANHOLE.

NOTIFICATIONS MADE:

MD DEPARTMENT OF ENVIRONMENT

PG COUNTY HEALTH DEPT

PG COUNTY MUNICIPALITIES

SIGNS POSTED: 4 POST DATE: 07/07/2026