



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3607992-073-2026

MDE OFFICIAL CONTACTED: KELLY KITCHENS #192134

DATA CALLED IN BY: ELBE L DAVIS DATE: 07/13/2026 AT 08:58PM

WORK ORDER(S): 3607992 3607982

EST DATE AND TIME SSO BEGAN: 07/13/2026 07:21PM DURATION: 4.15 HRS
DATE AND TIME SSO ENDED: 07/13/2026 11:30PM

SOURCE-CLEAN OUT 00378766000 WATER BODY AFFECTED-BROAD CREEK

CLOSEST STREET ADDRESS: 2815 MILL CROSSING DR 20744
COUNTY/PAGE/GRID: P 5765 G06 TOWN/CITY: FORT WASHINGTON

CAUSE: UNKNOWN EST OVERFLOW VOLUME: 30 GAL
UPON ARRIVAL, THE CREW SAW EVIDENCE THE PROPERTY LINE CLEANOUT HAD
RECENTLY OVERFLOWED ONTO THE GRASSY AREA AROUND THE CLEANOUT
APPROXIMATELY 30 TOTAL GALLONS. THE CREW INFORMED THE OCCUPANT TO
CEASE FROM USING FACILITIES UNTIL A WSSC CONTRACT PLUMBER ARRIVED
TO SNAKE AND CLEAR THE SEWER LATERAL, TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:
DRY WEATHER DISCOLORATION
PUBLIC ACCESS

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:
THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE
ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE
CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR
ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:
LIME

THE CREW SPREAD LIME IN THE GRASSY AREA AROUND THE CLEANOUT.

NOTIFICATIONS MADE:
MD DEPARTMENT OF ENVIRONMENT PG COUNTY HEALTH DEPT
PG COUNTY MUNICIPALITIES

SIGNS POSTED: 1 POST DATE: 07/14/2026