



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3611405-118-2026

MDE OFFICIAL CONTACTED: KEVIN

DATA CALLED IN BY: LAWRENCE E ROBINSON DATE: 07/30/2026 AT 06:07PM

WORK ORDER(S): 3611405 3611354

EST DATE AND TIME SSO BEGAN: 07/30/2026 11:46AM DURATION: 2.57 HRS
DATE AND TIME SSO ENDED: 07/30/2026 02:20PM

SOURCE-OVERFLOWING MH MH07004073 WATER BODY AFFECTED-CABIN JOHN

CLOSEST STREET ADDRESS: 26 WELLESLEY CIR
COUNTY/PAGE/GRID: M 5406 G05 TOWN/CITY: GLEN ECHO

CAUSE: ROOTS EST OVERFLOW VOLUME: 308 GAL
UPON ARRIVAL, THE CREW FOUND MANHOLE 071M OVERFLOWING AT
APPROXIMATELY 2 GPM AROUND THE RIM OF THE MANHOLE. THE CREW JETTED
FROM MANHOLE 073M TO 072U TO 017M, A TOTAL OF 268', AND HIT AND
RELIEVED HEAVY ROOTS THROUGHOUT THE MAINLINE, TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:
DISCOLORATION NOTICEABLE ODOR
PUBLIC ACCESS

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:
THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE
ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE
CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR
ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:
LIME

THE CREW SPREAD LIME IN THE GRASSY AREA AROUND THE MANHOLE.

NOTIFICATIONS MADE:
MD DEPARTMENT OF ENVIRONMENT DEP-MONTGOMERY COUNTY
MONTGOMERY CO MUNICIPALITIES

SIGNS POSTED: 3 POST DATE: 07/30/2026