



# WASHINGTON SUBURBAN SANITARY COMMISSION

## SANITARY SEWER OVERFLOW WRITTEN REPORT

3615209-118-2026

MDE OFFICIAL CONTACTED: OLUMIDE OGUNLEYE

DATA CALLED IN BY: BRANDON T MCCREA

DATE: 08/10/2026 AT 04:05PM

WORK ORDER(S): 3615209 3615165

EST DATE AND TIME SSO BEGAN: 08/10/2026 11:14AM DURATION: 2.60 HRS

DATE AND TIME SSO ENDED: 08/10/2026 01:50PM

SOURCE-OVERFLOWING MH MH14083033 WATER BODY AFFECTED-WESTERN BRANCH

CLOSEST STREET ADDRESS: 3136 PYLES DR 20774

COUNTY/PAGE/GRID: P 5652 B04 TOWN/CITY: UPPER MARLBORO

CAUSE: ROOTS

EST OVERFLOW VOLUME: 78 GAL

UPON ARRIVAL, THE CREW FOUND MANHOLE 033N OVERFLOWING ONTO THE MACADAM AROUND THE MANHOLE AND ONTO SURROUNDING GRASSY AREA. THE CREW JETTED FROM MANHOLE 032M TO 033N, A TOTAL OF 333', RELIEVING A ROOT OBSTRUCTION WITHIN MANHOLE 033N, TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DRY WEATHER

DISCOLORATION

NOTICEABLE ODOR

PUBLIC ACCESS

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

FLUSHED BACK INTO MANHOLE

LIME

THE CREW SPREAD LIME IN THE GRASSY AREA AROUND THE MANHOLE.

NOTIFICATIONS MADE:

MD DEPARTMENT OF ENVIRONMENT

PG COUNTY HEALTH DEPT

PG COUNTY MUNICIPALITIES

SIGNS POSTED: 1 POST DATE: 08/10/2026