



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3616271-118-2026

MDE OFFICIAL CONTACTED: KRISTY WAGNER

DATA CALLED IN BY: LAWRENCE E ROBINSON DATE: 08/14/2026 AT 04:26PM

WORK ORDER(S): 3616271 3616249

EST DATE AND TIME SSO BEGAN: 08/14/2026 02:50PM

DATE AND TIME SSO ENDED: 08/14/2026 04:30PM DURATION: 1.67 HRS

SOURCE-OVERFLOWING MH MH05118055 WATER BODY AFFECTED-ROCK CREEK

CLOSEST STREET ADDRESS: 12806 TURKEY BRANCH PKW 20853

COUNTY/PAGE/GRID: M 5165 G10 TOWN/CITY: ROCKVILLE

CAUSE: DEBRIS

EST OVERFLOW VOLUME: 200 GAL

UPON ARRIVAL, THE CREW FOUND MANHOLE 055M OVERFLOWING AT 5GPM ONTO THE GRASSY AREA AROUND THE MANHOLE AND INTO ROCK CREEK. THE CREW JETTED FROM MANHOLE 005U TO 055M A TOTAL OF 112' AND REMOVED A HARD DEBRIS BLOCKAGE, TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DRY WEATHER

DISCOLORATION

NOTICEABLE ODOR

PUBLIC ACCESS

NOTIFICATIONS MADE:

MD DEPARTMENT OF ENVIRONMENT
MONTGOMERY CO MUNICIPALITIES

DEP-MONTGOMERY COUNTY

SIGNS POSTED: 7 POST DATE: 08/14/2026