



WASHINGTON SUBURBAN SANITARY COMMISSION

SANITARY SEWER OVERFLOW WRITTEN REPORT

1101309-118-2026

MDE OFFICIAL CONTACTED: RYAN R.

DATA CALLED IN BY: SHEMIEKA HARDING

DATE: 8/31/2026 AT 06:04PM

WORK ORDER(S): 1043078

EST DATE AND TIME SSO BEGAN: 8/31/2026 05:34PM DURATION: 2.90 HRS

DATE AND TIME SSO ENDED: 8/31/2026 08:30PM

SOURCE-OVERFLOWING MH MH11047021 WATER BODY AFFECTED: BROAD CREEK

CLOSEST STREET ADDRESS: 3004 PLAZA DR 20746

COUNTY: PG TOWN/CITY: SUITLAND

CAUSE: GREASE AND WIPES

EST OVERFLOW VOLUME: 1975 GAL

UPON ARRIVAL, THE CREW FOUND MANHOLE 021U OVERFLOWING 5GPM ONTO THE SURROUNDING GRASSY AREA AND INTO A TRIBUTARY OF BROAD CREEK. THE CREW JETTED FROM MANHOLE 020M TO 021U, A TOTAL OF 279', AND HIT AND RELIEVED A HEAVY GREASE AND WIPES OBSTRUCTION INSIDE MANHOLE 021, TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DRY WEATHER DISCOLORATION NOTICABLE ODOR

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

LIME RAKED AREA REMOVED VISIBLE SOLIDS

THE CREW SPREAD LIME IN THE GRASSY AREA AROUND THE MANHOLE.

NOTIFICATIONS MADE:

MD DEPARTMENT OF ENVIRONMENT
PG COUNTY MUNICIPALITIES

PG COUNTY HEALTH DEPT

SIGNS POSTED: 5 POST DATE: 9/01/2026