



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

1104324 - 118 - 2026

MDE OFFICIAL CONTACTED: JAMES LYONS

DATA CALLED IN BY: DIARRA MACKALL

DATE: SEPT 13, 2026 3:01 PM

WORK ORDER(S): 1104324

EST DATE AND TIME SSO BEGAN: 09/13/2026 11:57 AM

DURATION: 2.3 HRS

DATE AND TIME SSO ENDED: 09/13/2026 02:00 PM

SOURCE - OVERFLOWING MANHOLE

WATER BODY AFFECTED: WESTERN BRANCH

CLOSEST STREET ADDRESS: 1415 PINELAKE LN, BOWIE, MD, 20716

COUNTY: P

TOWN/CITY: BOWIE

CAUSE: 14 DEBRIS

EST OVERFLOW VOLUME: 63 GAL

UPON ARRIVAL, THE CREW FOUND MANHOLE #025M OVERFLOWING AT .5 GPM INTO A NEARBY STORM DRAIN THAT OUTFALLS INTO WESTERN BRANCH. THE CREW JETTED FROM MANHOLE #022U TO MANHOLE #025M A TOTAL OF 88' TO RELIEVE BRICKS IN THE CHANNEL, ENDING THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

NO - NOTICEABLE ODOR, DIS - DISCOLORATION, PUO - PUBLIC USE OBSERVED, PA - PUBLIC ACCESS, DW - DRY WEATHER

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

FMH - FLUSHED BACK INTO MH

THE CREW DISINFECT AND FLUSHED LIQUID BACK IN MANHOLE.

NOTIFICATIONS MADE:

MDE - MD DEPT ENVIRONMENT

PG COUNTY HEALTH DEPT

PG COUNTY MUNICIPALITIES

SIGNS POSTED: 1

POST DATE: 09/13/2026