WASHINGTON SUBURBAN SANITARY COMMISSION
SANITARY SEWER OVERFLOW WRITTEN REPORT

1151623 - 118 - 2026

MDE OFFICIAL CONTACTED: CHRISTIE WAGNER

DATA CALLED IN BY: EDDIE GREEN

DATE: 10/26/2026 2:15 PM

WORK ORDER(S): 1151623

EST DATE AND TIME SSO BEGAN: N/A

DURATION: 0.0 HRS

DATE AND TIME SSO ENDED: N/A

SOURCE – OVERFLOWING MANHOLE 12019007U

WATER BODY AFFECTED: N/A

CLOSEST STREET ADDRESS: 5401 WESTBARD AVE, BETHESDA, MD, 20816

COUNTY: M

TOWN/CITY: BETHESDA

CAUSE: UNKOWN

EST OVERFLOW VOLUME: 0 GAL

UPON ARRIVAL, THE CREW FOUND MANHOLE 007U SUBMERGED IN WATER WITH THE SURROUNDING GRASSY AREA WET, GIVING THE APPEARANCE THAT THE MANHOLE WAS OVERFLOWING. UPON FURTHER INVESTIGATION, IT WAS DETERMINED THAT THE WATER WAS COMING FROM A 10-INCH PVC PIPE BEING USED TO PUMP GROUNDWATER FROM A NEARBY CONSTRUCTION SITE. NO SANITARY SEWER OVERFLOW OCCURRED; THEREFORE, THIS EVENT IS NON-REPORTABLE.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

NONE

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

N/A

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

NOTIFICATIONS MADE:

MDE - MD DEPT ENVIRONMENT

DEP - MONTGOMERY COUNTY DEP

MCM - MONTGOMERY MUNICIPALITIES

SIGNS POSTED: N/A

POST DATE: N/A

NON - REPORTABLE