

Combustion and Ventilation Air

Total Input	Unconfined space (8Ft.Ceiling/ Square Ft.)	Confined Space (Net Free Area of Louvers) (Min. Square Inches)
40,000	250	100
60,000	375	100
75,000	469	100
100,000	625	100
120,000	750	120
140,000	875	140
160,000	1000	160
180,000	1125	180
200,000	1250	200
220,000	1375	220
240,000	1500	240
260,000	1625	260
280,000	1750	280
300,000	1875	300
320,000	2000	320
340,000	2125	340
360,000	2250	360
380,000	2375	380
400,000	2500	400

Total BTU Of All Confined appliances
 ————— = Square Feet
 20 BTU per Cubic foot X Ceiling height