



NOTES:

1. REFER TO DETAIL W/7.5 WHEN METER AREA IS ADJACENT TO AN EXTERIOR WALL.
2. METER TO BE SET HORIZONTALLY.
3. NOMINAL DIMENSION: 3" METER, 1-3 FT; 4" AND LARGER METER, 1-2 FT.
4. METER NOT TO BE SET WITHIN 10' OF ELECTRICAL DISTRIBUTION EQUIPMENT.
5. TURBULENCE COMPENSATOR MIN. 5 PIPE DIA. INLET AND OUTLET.

WASHINGTON
SUBURBAN
SANITARY
COMMISSION

APPROVED: JULY 1, 2005

Rafael Rodriguez
Chief Engineer

STANDARD DETAIL

3" AND LARGER
INDOOR METER INSTALLATIONS

W
7.4