



Washington Suburban Sanitary Commission Collection System Discharge Written Report

6262901-118-2006

MDE OFFICIAL CONTACTED: JOANN

DATA CALLED IN BY: AMANDA A LEWIS

DATE: 05/27/2006 AT 08:32PM

WORK ORDER(S): 6262901 6262851

EST DATE AND TIME SSO BEGAN: 05/27/2006 04:14PM DURATION: 3.02 HRS

DATE AND TIME SSO ENDED: 05/27/2006 07:15PM

SOURCE: OVERFLOWING MH MH17010010 BASIN: PARKWAY

CLOSEST STREET ADDRESS: 14500 LAUREL-BOWIE RD 20715

COUNTY/PAGE/GRID: P 04 H05 TOWN/CITY: LAUREL

CAUSE: GREASE EST OVERFLOW VOLUME: 4,530 GAL
CREW JETTED 8" MAINLINE, HIT AND CLEARED GREASE AND RAG STOPPAGE FROM
MANHOLE 010M TO 056U.

<INITIAL CAUSE=13>

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DISCOLORATION

NOTICEABLE ODOR

DRY WEATHER

HAD DRY WEATHER WITH NOTICEABLE ODOR AND DISCOLORATION IN STREAM

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE
ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED
TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE
THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

NOTIFICATIONS MADE:

PG COUNTY HEALTH DEPT

MD DEPARTMENT OF ENVIRONMENT

NOTIFIED JOANN AT MDE AND PHD

SIGNS POSTED: 2 POST DATE: 05/27/2006