



Washington Suburban Sanitary Commission Collection System Discharge Written Report

6983571-118-2007

MDE OFFICIAL CONTACTED: GARY ZOUR

DATA CALLED IN BY: KISHA L COWARD

DATE: 05/05/2007 AT 01:59AM

WORK ORDER(S): 6983571 6983563

EST DATE AND TIME SSO BEGAN: 05/04/2007 10:37PM DURATION: 2.27 HRS

DATE AND TIME SSO ENDED: 05/05/2007 12:53AM

SOURCE: OVERFLOWING MH MH08061011 WATER BODY AFFECTED: NORTHEAST BRANCH

CLOSEST STREET ADDRESS: 10100 52ND AVE 20740-1124

COUNTY/PAGE/GRID: P 07 H05 TOWN/CITY: COLLEGE PARK

CAUSE: GREASE EST OVERFLOW VOLUME: 2 GAL

JETTED_FROM MANHOLE#_010U_TO MANHOLE#_011_FOUND_HEAVY GREASE AT 135'.
OVERFLOW ENTERED STORM DRAIN

<INITIAL CAUSE=13>

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DRY WEATHER

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

FLUSHED BACK INTO MANHOLE

WASHED DOWN STREET

NOTIFICATIONS MADE:

PG COUNTY HEALTH DEPT

MD DEPARTMENT OF ENVIRONMENT