



Washington Suburban Sanitary Commission Collection System Discharge Written Report

8979346-118-2009

MDE OFFICIAL CONTACTED: KATHY MOHAN

DATA CALLED IN BY: ELBE L DAVIS

DATE: 07/10/2009 AT 02:50PM

WORK ORDER(S): 8979346 8978975

EST DATE AND TIME SSO BEGAN: 07/10/2009 11:20AM DURATION: 2.67 HRS
DATE AND TIME SSO ENDED: 07/10/2009 02:00PM

SOURCE-OVERFLOWING MH MH15033115 WATER BODY AFFECTED-SENECA CREEK

CLOSEST STREET ADDRESS: 19550 MONTG VILLAGE AVE 20879
COUNTY/PAGE/GRID: M 5047 H02 TOWN/CITY: GAITHERSBURG

CAUSE: GREASE EST OVERFLOW VOLUME: 481 GAL
UPON ARRIVAL, THE INSPECTOR FOUND MANHOLE 115M OVERFLOWING
APPROXIMATELY 3 GPM. THE CREW JETTED FROM MANHOLE 114M TO 115M AND
RELIEVED A GREASE BLOCKAGE AT 120 FEET, ENDING THE OVERFLOW.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DRY WEATHER

NOTICEABLE ODOR

THE OVERFLOW ENTERED AN ON-SITE POND AT THE GOLF COURSE.

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE
ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED
TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE
THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

LIME

NOTIFICATIONS MADE:

DEP-MONTGOMERY COUNTY

MD DEPARTMENT OF ENVIRONMENT

SIGNS POSTED: 10 POST DATE: 07/10/2009