



Washington Suburban Sanitary Commission Collection System Discharge Written Report

8856858-072-2009

MDE OFFICIAL CONTACTED: KATHY MOHAN

DATA CALLED IN BY: ELBE L DAVIS

DATE: 05/08/2009 AT 08:56AM

WORK ORDER(S): 8856858 8856759

EST DATE AND TIME SSO BEGAN: 05/07/2009 04:45PM DURATION: 1.25 HRS

DATE AND TIME SSO ENDED: 05/07/2009 06:00PM

SOURCE-GRINDER PUMP 00350990800 WATER BODY AFFECTED-SENECA CREEK

CLOSEST STREET ADDRESS: 19509 JERUSALEM CH TER 20837

COUNTY/PAGE/GRID: M 5044 F04 TOWN/CITY: POOLESVILLE

CAUSE: INSTRUMENTATION/MECHANICAL FAI EST OVERFLOW VOLUME: 38 GAL

UPON ARRIVAL, THE CREW FOUND EVIDENCE OF AN OVERFLOW AROUND THE CLEAN
OUT ON PROPERTY. THE CAUSE OF THE OVERFLOW WAS DUE TO THE WSSC GRINDER
PUMP NOT FUNCTIONING PROPERLY.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DISCOLORATION

NOTICEABLE ODOR

PUBLIC ACCESS

PUBLIC USE OBSERVED

NO WATERWAYS AFFECTED.

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

A CREW REPAIRED THE BROKEN WSSC GRINDER PUMP.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

LIME

NOTIFICATIONS MADE:

DEP-MONTGOMERY COUNTY

MD DEPARTMENT OF ENVIRONMENT