



# Washington Suburban Sanitary Commission Collection System Discharge Written Report

9283466-073-2009

MDE OFFICIAL CONTACTED: CHUCK

DATA CALLED IN BY: DARREN S MAST

DATE: 11/26/2009 AT 12:35P

WORK ORDER(S): 9283466 9283391

EST DATE AND TIME SSO BEGAN: 11/26/2009 11:03AM DURATION: 1.25 HRS

DATE AND TIME SSO ENDED: 11/26/2009 12:18PM

SOURCE-CLEAN OUT 00404464000 WATER BODY AFFECTED-PISCATAWAY CREE

CLOSEST STREET ADDRESS: 5802 E BONIWOOD TURN 20735

COUNTY/PAGE/GRID: P 5882 E04 TOWN/CITY: CLINTON

CAUSE: UNKNOWN EST OVERFLOW VOLUME: 5 G

INSPECTOR ARRIVED AND FOUND CLEAN OUT OVERFLOWING. A WSSC PLUMBER WAS SENT TO SNAKE THE SERVICE. THE PLUMBER SNAKED AND RELIEVED AN UNKNOWN STOPPAGE AT 15 FEET, ENDING THE OVERFLOW.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DRY WEATHER

PUBLIC ACCESS

PUBLIC USE OBSERVED

NO WATERWAY AFFECTED.

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

RAKED AREA

LIME

CREW RETURNED ON 11/28/09, CLEANED UP AREA AND SPREAD 1/2 BAG OF LIME AROUND THE CLEAN OUT. NO SIGNS WERE NEEDED PER G HESS.

NOTIFICATIONS MADE:

PG COUNTY HEALTH DEPT

MD DEPARTMENT OF ENVIRONMENT