



Washington Suburban Sanitary Commission Collection System Discharge Written Report

9499849-109-2010

MDE OFFICIAL CONTACTED: CATHY MOHAN

DATA CALLED IN BY: KEVIN VERRETT

DATE: 03/02/2010 AT 11:45AM

WORK ORDER(S): 9499849 9499021

EST DATE AND TIME SSO BEGAN: 03/02/2010 07:56AM DURATION: 29.07 HRS
DATE AND TIME SSO ENDED: 03/03/2010 01:00PM

SOURCE-REPAIR SEWER MAIN SS15054211 WATER BODY AFFECTED-SENECA CREEK

CLOSEST STREET ADDRESS: 10401 LEWIS DR 20872-0000
COUNTY/PAGE/GRID: M 4809 F04 TOWN/CITY: DAMASCUS

CAUSE: UNKNOWN EST OVERFLOW VOLUME: 50 GAL
UPON ARRIVAL, CREWS JETTED A PRESSURE SEWER MAIN AND FOUND A SMALL
LEAK WITH SEWAGE SURFACING ONLY WHEN ONE OF THE THREE CUSTOMER'S
GRINDER PUMPS CAME ON. REPAIRS WERE MADE TO END THE OVERFLOW.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DRY WEATHER

NOTICEABLE ODOR

NO WATERWAY WAS IMPACTED.

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:
ON 03/03/10, A CREW REPLACED THREE FEET OF PIPE ON THIS PRESSURE
SEWER MAIN. DUE TO THE SIZE AND LINE UNDER PRESSURE, THIS
LINE IS NOT CCTVABLE.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

THE SOIL IMPACTED BY THE OVERFLOW WAS REMOVED WHEN THE AREA WAS
EXCAVATED FOR THE REPAIRS.

NOTIFICATIONS MADE:

DEP-MONTGOMERY COUNTY

MD DEPARTMENT OF ENVIRONMENT