



# Washington Suburban Sanitary Commission Collection System Discharge Written Report

0783712-072-2011

MDE OFFICIAL CONTACTED: GARY ZAMERSKI

DATA CALLED IN BY: ROBIN DESPANZA DATE: 08/22/2011 AT 09:18PM

WORK ORDER(S): 0783712 783613

EST DATE AND TIME SSO BEGAN: 08/22/2011 05:30PM DURATION: 1.00 HRS  
DATE AND TIME SSO ENDED: 08/22/2011 06:30PM

SOURCE-GRINDER PUMP 00320148000 WATER BODY AFFECTED-PAINT BRANCH

CLOSEST STREET ADDRESS: 15545 NEW HAMPSHIRE AVE 20904  
COUNTY/PAGE/GRID: M 5167 A03 TOWN/CITY: SILVER SPRING

CAUSE: UNKNOWN EST OVERFLOW VOLUME: 20 GAL  
CREW ARRIVED AND FOUND POSSIBLE BROKEN PIPE ON SERVICE FOR THE  
GRINDER PUMP ON THE STREET SIDE. NO OVERFLOW AT THE TIME OF ARRIVAL.  
REPAIRS MADE ON PRESSURE SEWER.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:  
DISCOLORATION

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:  
THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE  
ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED  
TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE  
THE CHANCE OF THIS LINE OVERFLOWING AGAIN. THIS OVERFLOW OCCURRED FROM  
A PRESSURE SEWER AND IS NOT CCTVABLE.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

NO SIGNS OR LIME WAS NEEDED

NOTIFICATIONS MADE:  
MD DEPARTMENT OF ENVIRONMENT DEP-MONTGOMERY COUNTY