



Washington Suburban Sanitary Commission Collection System Discharge Written Report

1180645-073-2012

MDE OFFICIAL CONTACTED: BRIAN

DATA CALLED IN BY: SHARON R JOYNER

DATE: 02/25/2012 AT 04:35PM

WORK ORDER(S): 1180645 1180603

EST DATE AND TIME SSO BEGAN: 02/25/2012 02:33PM DURATION: 4.95 HRS

DATE AND TIME SSO ENDED: 02/25/2012 07:30PM

SOURCE-CLEAN OUT 00465393700 WATER BODY AFFECTED-NORTHEAST BRANCH

CLOSEST STREET ADDRESS: 6630 AUBURN AVE 20737

COUNTY/PAGE/GRID: P 5410 G05 TOWN/CITY: RIVERDALE

CAUSE: UNKNOWN EST OVERFLOW VOLUME: 1 GAL

UPON THE CREW'S ARRIVAL, THE CLEANOUT AT THE PROPERTY LINE SHOWED EVIDENCE THAT IT HAD OVERFLOWED A TOTAL OF 1 GALLON. THE CREW SNAKED FROM THE CLEANOUT AT THE PROPERTY LINE A TOTAL OF 55 FEET RELIEVING A HARD UNKNOWN STOPPAGE AT 15 FEET, ENDING THE BACKUP.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DRY WEATHER

NOTICEABLE ODOR

PUBLIC ACCESS

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

LIME

RAKED AREA

NOTIFICATIONS MADE:

MD DEPARTMENT OF ENVIRONMENT

PG COUNTY HEALTH DEPT