



Washington Suburban Sanitary Commission Collection System Discharge Written Report

2252358-073-2014

MDE OFFICIAL CONTACTED: BRIAN

DATA CALLED IN BY: AMANDA A LEWIS

DATE: 01/11/2014 AT 07:05PM

WORK ORDER(S): 2252358 2252311

EST DATE AND TIME SSO BEGAN: 01/11/2014 01:34PM DURATION: 4.93 HRS

DATE AND TIME SSO ENDED: 01/11/2014 06:30PM

SOURCE-CLEAN OUT 00228798500 WATER BODY AFFECTED-WATTS BRANCH

CLOSEST STREET ADDRESS: 12236 ST JAMES RD 20854-2161

COUNTY/PAGE/GRID: M 5283 H02 TOWN/CITY: POTOMAC

CAUSE: DEBRIS EST OVERFLOW VOLUME: 2 GAL

UPON THE INSPECTOR'S ARRIVAL, RAGS WERE SEEN AROUND THE CLEANOUT LOCATED AT THE PROPERTY LINE WITH EVIDENCE IT HAD OVERFLOWED A TOTAL OF TWO GALLONS. THE CREW SNAKED FROM THE CLEANOUT A TOTAL OF 50 FEET, RELIEVING A RAG OBSTRUCTION AT 25 FEET, ENDING THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

WET WEATHER

PUBLIC USE OBSERVED

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

RAKED AREA

VISIBLE SOLIDS REMOVED

LIME

NOTIFICATIONS MADE:

MD DEPARTMENT OF ENVIRONMENT
DEP-MONTGOMERY COUNTY

MONTGOMERY CO MUNICIPALITIES