



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3028161-073-2021

MDE OFFICIAL CONTACTED: MARK BEALLE

DATA CALLED IN BY: RAVEN O YELDER

DATE: 01/30/2021 AT 02:23PM

WORK ORDER(S): 3028161 3027857

EST DATE AND TIME SSO BEGAN: 01/29/2021 03:02PM DURATION: 1.72 HRS

DATE AND TIME SSO ENDED: 01/29/2021 04:45PM

SOURCE-PRESSURE SEWER SERVICE 00395749500 WATER BODY AFFECTED-NORTHEAST BRANCH

CLOSEST STREET ADDRESS: 6004

CAMILLO CT

20737-3522

COUNTY/PAGE/GRID: P 5410 F05

TOWN/CITY: RIVERDALE

CAUSE: DEFECTIVE MATERIAL EST OVERFLOW VOLUME: 5 GAL

UPON ARRIVAL, THE INSPECTOR FOUND EVIDENCE OF 5 GALLONS OF LIQUID SEWAGE HAD OVERFLOWED FROM A VALVE BOX CONNECTED TO A PRESSURE SEWER SERVICE. THE CREW EXCAVATED AND FOUND THE 1.25 INCH PRESSURE SEWER SERVICE WAS BROKEN. THE CREW INSTALLED A NEW BALL VALVE AND REMOVED THE CHECK VALVE, ENDING THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

PUBLIC USE OBSERVED

DRY WEATHER

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THIS EVENT OCCURRED ON A PRESSURE SEWER SERVICE, AND IS THEREFORE NOT CCTVABLE. THE CREW INSTALLED A NEW BALL VALVE AND REMOVED THE CHECK VALVE. REPAIRS ARE COMPLETE.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

LIME

NOTIFICATIONS MADE:

MD DEPARTMENT OF ENVIRONMENT

PG COUNTY HEALTH DEPT

PG COUNTY MUNICIPALITIES

SIGNS POSTED: 1 POST DATE: 01/30/2021