


PLAN

NOTES:

1. SHC AT PROPERTY SHALL TERMINATE IN ACCORDANCE WITH DETAIL S/6.8.
2. SEE CONNECTION TO SEWER MAIN NOTES, DETAIL S/6.0.
3. USE T-WYE FOR ALL PROPOSED SHC WHEN MAIN LINE SEWER IS 1.0% OR LESS.
4. ORIENT T-WYE AS SHOWN WITH RESPECT TO FLOW.
5. FOR ELEVATION, SEE DETAIL S/6.2 AND S/6.3a.

WASHINGTON
SUBURBAN
SANITARY
COMMISSION

APPROVED: _____

9/27/16

Chief Engineer

STANDARD DETAIL

4-INCH AND 6-INCH
PVC HOUSE CONNECTIONS
AND FITTINGS

S
6.3