



#### NOTES:

1. USE ONLY DIP WITH SPECIAL INTERIOR LINING PER SPECIFICATIONS OR AWWA C900/905. FOR GROUTING PVC AWWA C900/905 SEE SPECIFICATIONS.
2. FOR SEWERS 10" AND SMALLER, PROVIDE THE FOLLOWING:  
OUTGOING SEWERS, PROVIDE 2'-0" LENGTH OF SPIGOT BY SPIGOT PIPE.  
INCOMING SEWERS, PROVIDE BELL BY SPIGOT PIPE WITH BELL EXTENDING 12" BEYOND THE MANHOLE.
3. SEE NOTES 1 THRU 9 ON DETAIL S/1.0

WASHINGTON  
SUBURBAN  
SANITARY  
COMMISSION

APPROVED:

7/29/16  
*[Signature]*  
Chief Engineer

STANDARD DETAIL

BENTONITE APPLICATION  
FOR GROUTED PIPE  
TO MANHOLE CONNECTION

S  
3.01