


NOTES:

1. THIS DETAIL SHALL BE USED WHEN WELDED-ON CONNECTIONS ARE PROVIDED FOR WATER MAIN BRANCH CONNECTIONS ON DUCTILE IRON WATER MAINS 24" AND LARGER AND FOR BLOWOFF CONNECTIONS TO WATER MAINS 24" TO 30" INSTALLED ACCORDING TO DETAILS W/3.0 AND W/3.04.
2. DO NOT ATTACH PIPE OR FITTINGS TO THE WELDED-ON CONNECTION UNTIL MAINLINE PIPE WITH THE CONNECTION IS SUPPORTED IN PLACE.
3. SUPPORT ALL PIPING ATTACHED TO THE WELDED-ON CONNECTION IMMEDIATELY AFTER INSTALLATION TO MINIMIZE LOAD TRANSMISSION TO THE CONNECTION.
4. FOR PIPE EMBEDMENT REQUIREMENTS FOR MAINLINE PIPE, SEE DETAIL M/8.1a AND M/8.1b.
5. RESTRAIN VALVE TO THE WELDED-ON CONNECTION, SEE SPECIFICATIONS.

WASHINGTON
SUBURBAN
SANITARY
COMMISSION

APPROVED:

9/28/16

Chief Engineer

STANDARD DETAIL
PIPING SUPPORT
AT WELDED-ON
CONNECTION

W
3.05