

- 1. FIRE HYDRANT HOSE CONNECTION SETTING FOR NON-TRAFFIC AREAS ONLY, DO NOT LOCATE IN SIDEWALK OR DRIVEWAY, UNLESS OTHERWISE NOTED ON THE DRAWINGS.
- 2. COMPACT BACKFILL AND AGGREGATE BASE AS STRUCTURAL FILL.
- 3. QUICK-DISCONNECT CAM AND GROOVE FITTINGS SHALL BE BRASS RATED AT 150 PSI AND IN ACCORDANCE WITH US MILITARY SPECIFICATIONS MIL-C-27487/US FEDERAL STANDARD A-A-59326.
- 4. RESTRAIN ALL JOINTS FROM MJ TEE TO 4" COMPANION FLANGED WITH WEDGE ACTION RESTRAINER GLANDS, SEE SPECIFICATIONS

WASHINGTON SUBURBAN SANITARY COMMISSION APPROVED: 9/25/16

STANDARD DETAIL
FIRE HOSE CONNECTION FOR
FM METER, ULTRASONIC METER,

И METER, ULTRASONIC METER AND DETECTOR CHECK VAULT LAYOUTS W 5.0f