



NOTES:

1. LOCATE END OF EXISTING ACP WATER MAIN. VERIFY OD OF EXISTING ACP WATER MAIN, WITH OD TOLERANCES OF COUPLING MANUFACTURER BEFORE REMOVING EXISTING WATER MAIN TO BE REPLACED.
2. TO BE CUT FROM THE SAME TYPE AND SIZE OF PIPE BEING SLEEVED.

WASHINGTON
SUBURBAN
SANITARY
COMMISSION

APPROVED: _____

Chief Engineer

STANDARD DETAIL

PIPE CLOSURE
JOINT DETAIL
FOR EXIST. ACP WATER MAINS

W
11.1