

**WSSC TAP WATER ANALYSIS - 2017**

<b>PATUXENT WATER FILTRATION PLANT</b>					
<b>PARAMETER</b>	<b>UNIT OF MEASURE</b>	<b>YEARLY AVERAGE</b>	<b>MAXIMUM</b>	<b>MINIMUM</b>	<b>EPA LIMIT <sup>11</sup></b>
<b><u>GENERAL WATER QUALITY</u></b>					
Alkalinity	mg/L	34	39	29	
Color	Units	1	10	0	15 (SMCL)
Hardness	mg/L	76	124	52	
pH	S.U.	7.4	7.8	7.1	6.5-8.5 (SMCL)
Specific Conductance	MicroSiemens/cm	214	472	174	
Temperature	° C	16.5	28.1	4.3	
Threshold Odor	Units	1.0	1.0	1.0	3 (SMCL)
Turbidity <sup>1</sup>	NTU	0.04	0.09	0.01	TT=1 NTU; <0.3 NTU 95% of time
Geosmin	ng/L	3.9	8.9	n/d	
2-Methylisoborneol	ng/L	2.9	13.1	n/d	
<b><u>METALS</u></b>					
Aluminum	µg/L	17.42	24.9	10.8	200 (SMCL)
Antimony	µg/L	n/d	n/d	n/d	6
Arsenic	µg/L	<2	<2	n/d	10
Barium	mg/L	0.026	0.028	0.0231	2
Beryllium	µg/L	n/d	n/d	n/d	4
Cadmium	µg/L	n/d	n/d	n/d	5
Calcium	mg/L	16.63	19	15	
Total Chromium	µg/L	<2	<2	n/d	100
Copper	mg/L	0.011	0.014	0.007	
Iron	mg/L	<0.2	<0.2	n/d	0.3 (SMCL)
Lead	µg/L	<2	<2	n/d	
Magnesium	mg/L	5.04	5.6	3.7	
Manganese	µg/L	<2	2.42	n/d	50 (SMCL)
Mercury	µg/L	n/d	n/d	n/d	2
Nickel	µg/L	<2	<2	n/d	
Potassium	mg/L	3.06	3.6	2.3	
Selenium	µg/L	n/d	n/d	n/d	50
Silicon	mg/L	1.89	3.85	0.26	
Silver	µg/L	n/d	n/d	n/d	100 (SMCL)
Sodium	mg/L	12.87	16	10	
Thallium	µg/L	n/d	n/d	n/d	2
Zinc	µg/L	<2	<2	n/d	5000 (SMCL)
<b><u>INORGANICS</u></b>					
Boron	mg/L	0.008	0.013	0.005	
Chloride	mg/L	35.4	41.3	30.2	250 (SMCL)
Residual Chlorine	mg/L	1.3	1.8	0.3	TT=>0.2
Fluoride	mg/L	0.65	0.73	0.51	4 (SMCL=2)
Nitrate	mg/L	0.94	1.38	0.48	10
Nitrite	mg/L	n/d	n/d	n/d	1
Phosphorus	mg/L	0.33	0.39	0.201	
Sulfate	mg/L	7.1	22.0	4.6	250 (SMCL)
<b><u>DISINFECTION BYPRODUCT PRECURSOR</u></b>					
Total Organic Carbon	mg/L	1.6	2.3	1.0	TT
<b><u>ORGANICS</u></b>					
Haloacetic Acids (HAA5)	µg/L	20.3	29.7	10.6	
Total Trihalomethanes (TTHMs)	µg/L	23.4	35.8	10.1	
<b><u>PESTICIDES &amp; SYNTHETIC ORGANIC CHEMICALS (SOCs)</u></b>					
2,3,7,8-TCDD (Dioxin)	pg/L	n/d	n/d	n/d	30
2,4,5 TP (Silvex)	µg/L	n/d	n/d	n/d	50
2,4-D	µg/L	n/d	n/d	n/d	70
3-Hydroxycarbofuran	µg/L	n/d	n/d	n/d	
Alachlor	µg/L	n/d	n/d	n/d	2

**WSSC TAP WATER ANALYSIS - 2017**

<b>PATUXENT WATER FILTRATION PLANT</b>					
<b>PARAMETER</b>	<b>UNIT OF MEASURE</b>	<b>YEARLY AVERAGE</b>	<b>MAXIMUM</b>	<b>MINIMUM</b>	<b>EPA LIMIT <sup>11</sup></b>
<b><u>PESTICIDES &amp; SYNTHETIC ORGANIC CHEMICALS (SOCs)</u></b>					
Aldicarb	µg/L	n/d	n/d	n/d	3
Aldicarb sulfone	µg/L	n/d	n/d	n/d	2
Aldicarb sulfoxide	µg/L	n/d	n/d	n/d	4
Aldrin	µg/L	n/d	n/d	n/d	
Atrazine	µg/L	<1	<1	n/d	3
Benzo(a)pyrene	µg/L	n/d	n/d	n/d	0.2
Butachlor	µg/L	n/d	n/d	n/d	
Carbaryl	µg/L	n/d	n/d	n/d	
Carbofuran	µg/L	n/d	n/d	n/d	40
Chlorinated biphenyls (PCBs)	µg/L	n/d	n/d	n/d	0.5
Chlordane	µg/L	n/d	n/d	n/d	2
Dalapon	µg/L	<1	<1	n/d	200
Dibromochloropropane (DBCP)	µg/L	n/d	n/d	n/d	0.2
Dicamba	µg/L	n/d	n/d	n/d	
Dieldrin	µg/L	n/d	n/d	n/d	
Di(2-ethylhexyl)adipate	µg/L	n/d	n/d	n/d	400
Di(2-ethylhexyl)phthalate	µg/L	<2	<2	n/d	6
Dinoseb	µg/L	n/d	n/d	n/d	7
Diquat	µg/L	n/d	n/d	n/d	20
1,2-Dibromoethane (EDB)	µg/L	n/d	n/d	n/d	0.05
Endothall	µg/L	n/d	n/d	n/d	100
Endrin	µg/L	n/d	n/d	n/d	2
Glyphosate	µg/L	n/d	n/d	n/d	700
Heptachlor	µg/L	n/d	n/d	n/d	0.4
Heptachlor epoxide	µg/L	n/d	n/d	n/d	0.2
Hexachlorobenzene	µg/L	n/d	n/d	n/d	1
Hexachlorocyclopentadiene	µg/L	n/d	n/d	n/d	50
Lindane	µg/L	n/d	n/d	n/d	0.2
Metolachlor	µg/L	n/d	n/d	n/d	
Methomyl	µg/L	n/d	n/d	n/d	
Methoxychlor	µg/L	n/d	n/d	n/d	40
Metribuzin	µg/L	n/d	n/d	n/d	
Oxamyl (vydate)	µg/L	n/d	n/d	n/d	200
Pentachlorophenol (PCP)	µg/L	n/d	n/d	n/d	1
Picloram	µg/L	n/d	n/d	n/d	500
Propachlor	µg/L	n/d	n/d	n/d	
Simazine	µg/L	<1	<1	n/d	4
Toxaphene	µg/L	n/d	n/d	n/d	3
<b><u>VOLATILE ORGANIC CHEMICALS (VOCs)</u></b>					
1,1,1-Trichloroethane	µg/L	n/d	n/d	n/d	200
1,1,2-Trichloroethane	µg/L	n/d	n/d	n/d	5
1,1-Dichloroethene	µg/L	n/d	n/d	n/d	7
1,2,4-Trichlorobenzene	µg/L	n/d	n/d	n/d	70
1,2-Dichlorobenzene	µg/L	n/d	n/d	n/d	600
1,2-Dichloroethane	µg/L	n/d	n/d	n/d	5
1,2-Dichloropropane	µg/L	n/d	n/d	n/d	5
1,4-Dichlorobenzene	µg/L	n/d	n/d	n/d	75
Benzene	µg/L	n/d	n/d	n/d	5
Carbon Tetrachloride	µg/L	n/d	n/d	n/d	5
Chlorobenzene	µg/L	n/d	n/d	n/d	100
<i>cis</i> -1,2-Dichloroethene	µg/L	n/d	n/d	n/d	70
Dichloromethane	µg/L	n/d	n/d	n/d	5
Ethylbenzene	µg/L	n/d	n/d	n/d	700
Total Xylenes	µg/L	n/d	n/d	n/d	10000
Styrene	µg/L	n/d	n/d	n/d	100

**WSSC TAP WATER ANALYSIS - 2017**

<b>PATUXENT WATER FILTRATION PLANT</b>					
<b>PARAMETER</b>	<b>UNIT OF MEASURE</b>	<b>YEARLY AVERAGE</b>	<b>MAXIMUM</b>	<b>MINIMUM</b>	<b>EPA LIMIT <sup>11</sup></b>

**VOLATILE ORGANIC CHEMICALS (VOCs)**

Tetrachloroethene	µg/L	n/d	n/d	n/d	5
Toluene	µg/L	n/d	n/d	n/d	1000
<i>trans</i> -1,2-Dichloroethene	µg/L	n/d	n/d	n/d	100
Trichloroethene	µg/L	n/d	n/d	n/d	5
Vinyl Chloride	µg/L	n/d	n/d	n/d	2
1,1,1,2-Tetrachloroethane	µg/L	n/d	n/d	n/d	
1,1,2,2-Tetrachloroethane	µg/L	n/d	n/d	n/d	
1,1-Dichloroethane	µg/L	n/d	n/d	n/d	
1,1-Dichloropropene	µg/L	n/d	n/d	n/d	
1,2,3-Trichlorobenzene	µg/L	n/d	n/d	n/d	
1,2,3-Trichloropropane	µg/L	n/d	n/d	n/d	
1,2,4-Trimethylbenzene	µg/L	n/d	n/d	n/d	
1,3,5-Trimethylbenzene	µg/L	n/d	n/d	n/d	
1,3-Dichlorobenzene	µg/L	n/d	n/d	n/d	
1,3-Dichloropropane	µg/L	n/d	n/d	n/d	
2,2-Dichloropropane	µg/L	n/d	n/d	n/d	
2-Chlorotoluene	µg/L	n/d	n/d	n/d	
4-Chlorotoluene	µg/L	n/d	n/d	n/d	
Bromobenzene	µg/L	n/d	n/d	n/d	
Bromochloromethane	µg/L	n/d	n/d	n/d	
Bromomethane	µg/L	n/d	n/d	n/d	
Chloroethane	µg/L	n/d	n/d	n/d	
Chloromethane	µg/L	n/d	n/d	n/d	
<i>cis</i> -1,3-Dichloropropene	µg/L	n/d	n/d	n/d	
Dibromomethane	µg/L	n/d	n/d	n/d	
Dichlorodifluoromethane	µg/L	n/d	n/d	n/d	
Hexachlorobutadiene	µg/L	n/d	n/d	n/d	
Isopropylbenzene	µg/L	n/d	n/d	n/d	
n-Butylbenzene	µg/L	n/d	n/d	n/d	
n-Propylbenzene	µg/L	n/d	n/d	n/d	
Naphthalene	µg/L	n/d	n/d	n/d	
p-Isopropyltoluene	µg/L	n/d	n/d	n/d	
s-Butylbenzene	µg/L	n/d	n/d	n/d	
t-Butylbenzene	µg/L	n/d	n/d	n/d	
<i>trans</i> -1,3-Dichloropropene	µg/L	n/d	n/d	n/d	
Trichlorofluoromethane	µg/L	n/d	n/d	n/d	
Nitrobenzene	µg/L	n/d	n/d	n/d	
Methyl-tert-butyl-ether	µg/L	n/d	n/d	n/d	

**RADIONUCLIDES**

Gross Alpha	pCi/L	<2	<2	<2	15
Gross Beta	pCi/L	4.4	<4	5.2	50 <sup>2</sup>
Radium 228	pCi/L	1	<1	3	5 <sup>3</sup>
Tritium	pCi/L	<100	<100	<100	

**CUSTOMER TAP <sup>4</sup>**

<b>PARAMETER</b>	<b>UNIT OF MEASURE</b>	<b>90th PERCENTILE <sup>5</sup></b>	<b># of SITES ABOVE AL</b>	<b>EPA ACTION LEVEL (AL)</b>
Copper	µg/L	0.101	0	1300
Lead	µg/L	1.05	1	15

**DISTRIBUTION SYSTEM**

<b>PARAMETER</b>	<b>UNIT OF MEASURE</b>	<b>YEARLY AVERAGE</b>	<b>MAXIMUM</b>	<b>MINIMUM</b>	<b>EPA LIMIT <sup>11</sup></b>
------------------	------------------------	-----------------------	----------------	----------------	--------------------------------

**BACTERIOLOGICAL**

Samples Total Coliform Positive	%/month	0.16	0.53	0	5
Samples <i>E. coli</i> Positive	%/month	0	0	0	

## WSSC TAP WATER ANALYSIS - 2017

<b>DISTRIBUTION SYSTEM</b>					
<b>PARAMETER</b>	<b>UNIT OF MEASURE</b>	<b>YEARLY AVERAGE</b>	<b>MAXIMUM</b>	<b>MINIMUM</b>	<b>EPA LIMIT <sup>11</sup></b>
<b><u>BACTERIOLOGICAL</u></b>					
No. of <i>E. coli</i> Positive Routine Samples	Count	0	0	0	
No. of <i>E. coli</i> Positive Repeat Samples	Count	0	0	0	0
<b><u>DISINFECTANT &amp; DISINFECTION BYPRODUCTS</u></b>					
Residual Chlorine	mg/L	1.22	3.40	0 <sup>7</sup>	4 <sup>8</sup>
Haloacetic Acids (HAA5)	µg/L	51.4	91.2	14.3	60 <sup>10</sup>
Total Trihalomethanes (TTHMs)	µg/L	65.1	115.1	21.7	80 <sup>10</sup>

### **LEGENDS**

n/d - not detected

mg/L - milligrams per liter, equal to parts per million (ppm). The equivalent of one minute in 2 years or one penny in \$10,000.

µg/L - micrograms per liter, equal to parts per billion (ppb). The equivalent of one minute in 2,000 years or one penny in \$10 million.

ng/L - nanograms per liter, equal to parts per trillion (ppt). The equivalent of one minute in 2,000,000 years or one penny in \$10 billion.

pg/L - picograms per liter, equal to parts per quadrillion (ppq). The equivalent of one minute in 2,000,000,000 years or one penny in \$10 trillion.

pCi/L - picocuries per liter ( a measure of radiation)

S.U. - Standard Unit

NTU - Nephelometric Turbidity Unit

TT - Treatment Technique. A required process intended to reduce the level of a contaminant in drinking water.

AL - Action level. The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

= equals

< less than

<sup>1</sup> - Filtered water, maximum of measurements taken every 15 minutes.

<sup>2</sup> - EPA considers 50 pCi/L to be the level of concern for beta particles.

<sup>3</sup> - The EPA limit of 5 pCi/L applies to combined Radium 226 and 228.

<sup>4</sup> - Most recent required sampling, between June and September 2014.

<sup>5</sup> - If more than 10% of sites exceed action level, system is required to take additional steps to control corrosiveness of their water.

<sup>6</sup> - Highest running annual average (RAA)

<sup>7</sup> - All samples deemed to have detectable disinfectant residual.

<sup>8</sup> - Maximum residual disinfectant level (MRDL), the highest level of a disinfectant allowed in drinking water; based on RAA.

<sup>9</sup> - Highest locational running annual average (LRAA)

<sup>10</sup> - Maximum contaminant level based on LRAA.

<sup>11</sup> - Shown as maximum contaminant levels (MCL) unless otherwise noted as secondary MCLs (SMCL). MCLs are enforceable health-based standards, whereas SMCLs are non-enforceable guidelines for contaminants that may cause aesthetic effects in drinking water.

## WSSC TAP WATER ANALYSIS - 2017

<b>POTOMAC WATER FILTRATION PLANT</b>					
<b>PARAMETER</b>	<b>UNIT OF MEASURE</b>	<b>YEARLY AVERAGE</b>	<b>MAXIMUM</b>	<b>MINIMUM</b>	<b>EPA LIMIT <sup>11</sup></b>
<b><u>GENERAL WATER QUALITY</u></b>					
Alkalinity	mg/L	79	115	46	
Color	Units	1	7	0	15 (SMCL)
Hardness	mg/L	142	190	86	
pH	S.U.	7.3	7.6	7.1	6.5-8.5 (SMCL)
Specific Conductance	MicroSiemens/cm	383	492	223	
Temperature	° C	16.2	31.2	1.6	
Threshold Odor	Units	1.0	3.2	1.0	3 (SMCL)
Turbidity <sup>1</sup>	NTU	0.04	0.17	0.02	TT=1 NTU; <0.3 NTU 95% of time
<b><u>METALS</u></b>					
Aluminum	µg/L	50.43	154	13.10	200 (SMCL)
Antimony	µg/L	n/d	n/d	n/d	6
Arsenic	µg/L	<2	<2	n/d	10
Barium	mg/L	0.033	0.041	0.027	2
Beryllium	µg/L	n/d	n/d	n/d	4
Cadmium	µg/L	n/d	n/d	n/d	5
Calcium	mg/L	38.3	49.0	26.0	
Total Chromium	µg/L	<2	<2	n/d	100
Copper	mg/L	<0.002	0.002	<0.002	
Iron	mg/L	<0.2	<0.2	n/d	0.3 (SMCL)
Lead	µg/L	<2	<2	n/d	
Magnesium	mg/L	8.8	15.0	4.6	
Manganese	µg/L	8.79	35	<2	50 (SMCL)
Mercury	µg/L	n/d	n/d	n/d	2
Nickel	µg/L	2.25	3.44	<2	
Potassium	mg/L	3.6	4.9	2.3	
Selenium	µg/L	<2	<2	n/d	50
Silicon	mg/L	2.4	3.5	0.7	
Silver	µg/L	n/d	n/d	n/d	100 (SMCL)
Sodium	mg/L	17.6	26.0	11.0	
Thallium	µg/L	n/d	n/d	n/d	2
Zinc	µg/L	<2	2.35	n/d	5000 (SMCL)
<b><u>INORGANICS</u></b>					
Boron	mg/L	0.023	0.032	0.016	
Chloride	mg/L	42.3	61.9	25.9	250 (SMCL)
Residual Chlorine	mg/L	1.5	2.5	0.2	TT=>0.2
Fluoride	mg/L	0.64	0.82	0.50	4 (SMCL=2)
Nitrate	mg/L	1.24	1.58	0.71	10
Nitrite	mg/L	n/d	n/d	n/d	1
Phosphorus	mg/L	0.27	0.34	0.22	
Sulfate	mg/L	37.5	52.3	19.4	250 (SMCL)
<b><u>DISINFECTION BYPRODUCT PRECURSOR</u></b>					
Total Organic Carbon	mg/L	2.1	4.0	1.4	TT
<b><u>ORGANICS</u></b>					
Haloacetic Acids (HAA5)	µg/L	19.5	38.7	8.9	
Total Trihalomethanes (TTHMs)	µg/L	21.2	40.6	10.1	
<b><u>PESTICIDES &amp; SYNTHETIC ORGANIC CHEMICALS (SOCs)</u></b>					
2,3,7,8-TCDD (Dioxin)	pg/L	n/d	n/d	n/d	30
2,4,5 TP (Silvex)	µg/L	n/d	n/d	n/d	50
2,4-D	µg/L	n/d	n/d	n/d	70
3-Hydroxycarbofuran	µg/L	n/d	n/d	n/d	
Alachlor	µg/L	n/d	n/d	n/d	2
Aldicarb	µg/L	n/d	n/d	n/d	3
Aldicarb sulfone	µg/L	n/d	n/d	n/d	2

## WSSC TAP WATER ANALYSIS - 2017

<b>POTOMAC WATER FILTRATION PLANT</b>					
<b>PARAMETER</b>	<b>UNIT OF MEASURE</b>	<b>YEARLY AVERAGE</b>	<b>MAXIMUM</b>	<b>MINIMUM</b>	<b>EPA LIMIT <sup>11</sup></b>
<b><u>PESTICIDES &amp; SYNTHETIC ORGANIC CHEMICALS (SOCs)</u></b>					
Aldicarb sulfoxide	µg/L	n/d	n/d	n/d	4
Aldrin	µg/L	n/d	n/d	n/d	
Atrazine	µg/L	n/d	n/d	n/d	3
Benzo(a)pyrene	µg/L	n/d	n/d	n/d	0.2
Butachlor	µg/L	n/d	n/d	n/d	
Carbaryl	µg/L	n/d	n/d	n/d	
Carbofuran	µg/L	n/d	n/d	n/d	40
Chlorinated biphenyls (PCBs)	µg/L	n/d	n/d	n/d	0.5
Chlordane	µg/L	n/d	n/d	n/d	2
Dalapon	µg/L	<1	<1	n/d	200
Dibromochloropropane (DBCP)	µg/L	n/d	n/d	n/d	0.2
Dicamba	µg/L	n/d	n/d	n/d	
Dieldrin	µg/L	n/d	n/d	n/d	
Di(2-ethylhexyl)adipate	µg/L	n/d	n/d	n/d	400
Di(2-ethylhexyl)phthalate	µg/L	n/d	n/d	n/d	6
Dinoseb	µg/L	n/d	n/d	n/d	7
Diquat	µg/L	n/d	n/d	n/d	20
1,2-Dibromoethane (EDB)	µg/L	n/d	n/d	n/d	0.05
Endothall	µg/L	n/d	n/d	n/d	100
Endrin	µg/L	n/d	n/d	n/d	2
Glyphosate	µg/L	n/d	n/d	n/d	700
Heptachlor	µg/L	n/d	n/d	n/d	0.4
Heptachlor epoxide	µg/L	n/d	n/d	n/d	0.2
Hexachlorobenzene	µg/L	n/d	n/d	n/d	1
Hexachlorocyclopentadiene	µg/L	n/d	n/d	n/d	50
Lindane	µg/L	n/d	n/d	n/d	0.2
Metolachlor	µg/L	n/d	n/d	n/d	
Methomyl	µg/L	n/d	n/d	n/d	
Methoxychlor	µg/L	n/d	n/d	n/d	40
Metribuzin	µg/L	n/d	n/d	n/d	
Oxamyl (vydate)	µg/L	n/d	n/d	n/d	200
Pentachlorophenol (PCP)	µg/L	n/d	n/d	n/d	1
Picloram	µg/L	n/d	n/d	n/d	500
Propachlor	µg/L	n/d	n/d	n/d	
Simazine	µg/L	n/d	n/d	n/d	4
Toxaphene	µg/L	n/d	n/d	n/d	3
<b><u>VOLATILE ORGANIC CHEMICALS (VOCs)</u></b>					
1,1,1-Trichloroethane	µg/L	n/d	n/d	n/d	200
1,1,2-Trichloroethane	µg/L	n/d	n/d	n/d	5
1,1-Dichloroethene	µg/L	n/d	n/d	n/d	7
1,2,4-Trichlorobenzene	µg/L	n/d	n/d	n/d	70
1,2-Dichlorobenzene	µg/L	n/d	n/d	n/d	600
1,2-Dichloroethane	µg/L	n/d	n/d	n/d	5
1,2-Dichloropropane	µg/L	n/d	n/d	n/d	5
1,4-Dichlorobenzene	µg/L	n/d	n/d	n/d	75
Benzene	µg/L	n/d	n/d	n/d	5
Carbon Tetrachloride	µg/L	n/d	n/d	n/d	5
Chlorobenzene	µg/L	n/d	n/d	n/d	100
<i>cis</i> -1,2-Dichloroethene	µg/L	n/d	n/d	n/d	70
Dichloromethane	µg/L	n/d	n/d	n/d	5
Ethylbenzene	µg/L	n/d	n/d	n/d	700
Total Xylenes	µg/L	n/d	n/d	n/d	10000
Styrene	µg/L	n/d	n/d	n/d	100
Tetrachloroethene	µg/L	n/d	n/d	n/d	5
Toluene	µg/L	n/d	n/d	n/d	1000

**WSSC TAP WATER ANALYSIS - 2017**

<b>POTOMAC WATER FILTRATION PLANT</b>					
<b>PARAMETER</b>	<b>UNIT OF MEASURE</b>	<b>YEARLY AVERAGE</b>	<b>MAXIMUM</b>	<b>MINIMUM</b>	<b>EPA LIMIT <sup>11</sup></b>

**VOLATILE ORGANIC CHEMICALS (VOCs)**

<i>trans</i> -1,2-Dichloroethene	µg/L	n/d	n/d	n/d	100
Trichloroethene	µg/L	n/d	n/d	n/d	5
Vinyl Chloride	µg/L	n/d	n/d	n/d	2
1,1,1,2-Tetrachloroethane	µg/L	n/d	n/d	n/d	
1,1,2,2-Tetrachloroethane	µg/L	n/d	n/d	n/d	
1,1-Dichloroethane	µg/L	n/d	n/d	n/d	
1,1-Dichloropropene	µg/L	n/d	n/d	n/d	
1,2,3-Trichlorobenzene	µg/L	n/d	n/d	n/d	
1,2,3-Trichloropropane	µg/L	n/d	n/d	n/d	
1,2,4-Trimethylbenzene	µg/L	n/d	n/d	n/d	
1,3,5-Trimethylbenzene	µg/L	n/d	n/d	n/d	
1,3-Dichlorobenzene	µg/L	n/d	n/d	n/d	
1,3-Dichloropropane	µg/L	n/d	n/d	n/d	
2,2-Dichloropropane	µg/L	n/d	n/d	n/d	
2-Chlorotoluene	µg/L	n/d	n/d	n/d	
4-Chlorotoluene	µg/L	n/d	n/d	n/d	
Bromobenzene	µg/L	n/d	n/d	n/d	
Bromochloromethane	µg/L	n/d	n/d	n/d	
Bromomethane	µg/L	n/d	n/d	n/d	
Chloroethane	µg/L	n/d	n/d	n/d	
Chloromethane	µg/L	n/d	n/d	n/d	
<i>cis</i> -1,3-Dichloropropene	µg/L	n/d	n/d	n/d	
Dibromomethane	µg/L	n/d	n/d	n/d	
Dichlorodifluoromethane	µg/L	n/d	n/d	n/d	
Hexachlorobutadiene	µg/L	n/d	n/d	n/d	
Isopropylbenzene	µg/L	n/d	n/d	n/d	
n-Butylbenzene	µg/L	n/d	n/d	n/d	
n-Propylbenzene	µg/L	n/d	n/d	n/d	
Naphthalene	µg/L	n/d	n/d	n/d	
p-Isopropyltoluene	µg/L	n/d	n/d	n/d	
s-Butylbenzene	µg/L	n/d	n/d	n/d	
t-Butylbenzene	µg/L	n/d	n/d	n/d	
<i>trans</i> -1,3-Dichloropropene	µg/L	n/d	n/d	n/d	
Trichlorofluoromethane	µg/L	n/d	n/d	n/d	
Nitrobenzene	µg/L	n/d	n/d	n/d	
Methyl-tert-butyl-ether	µg/L	n/d	n/d	n/d	

**RADIONUCLIDES**

Gross Alpha	pCi/L	<2	<2	<2	15
Gross Beta	pCi/L	4.1	<4	4.2	50 <sup>2</sup>
Radium 228	pCi/L	1.03	<1	1.1	5 <sup>3</sup>
Tritium	pCi/L	<100	<100	<100	

**CUSTOMER TAP <sup>4</sup>**

<b>PARAMETER</b>	<b>UNIT OF MEASURE</b>	<b>90th PERCENTILE <sup>5</sup></b>	<b># of SITES ABOVE AL</b>	<b>EPA ACTION LEVEL (AL)</b>
Copper	µg/L	0.101	0	1300
Lead	µg/L	1.05	1	15

**DISTRIBUTION SYSTEM**

<b>PARAMETER</b>	<b>UNIT OF MEASURE</b>	<b>YEARLY AVERAGE</b>	<b>MAXIMUM</b>	<b>MINIMUM</b>	<b>EPA LIMIT <sup>11</sup></b>
------------------	------------------------	-----------------------	----------------	----------------	--------------------------------

**BACTERIOLOGICAL**

Samples Total Coliform Positive	%/month	0.16	0.53	0	5
Samples <i>E. coli</i> Positive	%/month	0	0	0	

## WSSC TAP WATER ANALYSIS - 2017

<b>DISTRIBUTION SYSTEM</b>					
<b>PARAMETER</b>	<b>UNIT OF MEASURE</b>	<b>YEARLY AVERAGE</b>	<b>MAXIMUM</b>	<b>MINIMUM</b>	<b>EPA LIMIT <sup>11</sup></b>
<b><u>BACTERIOLOGICAL</u></b>					
No. of <i>E. coli</i> Positive Routine Samples	Count	0	0	0	
No. of <i>E. coli</i> Positive Repeat Samples	Count	0	0	0	0
<b><u>DISINFECTANT &amp; DISINFECTION BYPRODUCTS</u></b>					
Residual Chlorine	mg/L	1.22	3.40	0 <sup>7</sup>	4 <sup>8</sup>
Haloacetic Acids (HAA5)	µg/L	51.4	91.2	14.3	60 <sup>10</sup>
Total Trihalomethanes (TTHMs)	µg/L	65.1	115.1	21.7	80 <sup>10</sup>

### **LEGENDS**

n/d - not detected

mg/L - milligrams per liter, equal to parts per million (ppm). The equivalent of one minute in 2 years or one penny in \$10,000.

µg/L - micrograms per liter, equal to parts per billion (ppb). The equivalent of one minute in 2,000 years or one penny in \$10 million.

ng/L - nanograms per liter, equal to parts per trillion (ppt). The equivalent of one minute in 2,000,000 years or one penny in \$10 billion.

pg/L - picograms per liter, equal to parts per quadrillion (ppq). The equivalent of one minute in 2,000,000,000 years or one penny in \$10 trillion.

pCi/L - picocuries per liter ( a measure of radiation)

S.U. - Standard Unit

NTU - Nephelometric Turbidity Unit

TT - Treatment Technique. A required process intended to reduce the level of a contaminant in drinking water.

AL - Action level. The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

= equals

< less than

<sup>1</sup> - Filtered water, maximum of measurements taken every 15 minutes.

<sup>2</sup> - EPA considers 50 pCi/L to be the level of concern for beta particles.

<sup>3</sup> - The EPA limit of 5 pCi/L applies to combined Radium 226 and 228.

<sup>4</sup> - Most recent required sampling, between June and September 2014.

<sup>5</sup> - If more than 10% of sites exceed action level, system is required to take additional steps to control corrosiveness of their water.

<sup>6</sup> - Highest running annual average (RAA)

<sup>7</sup> - All samples deemed to have detectable disinfectant residual.

<sup>8</sup> - Maximum residual disinfectant level (MRDL), the highest level of a disinfectant allowed in drinking water; based on RAA.

<sup>9</sup> - Highest locational running annual average (LRAA)

<sup>10</sup> - Maximum contaminant level based on LRAA.

<sup>11</sup> - Shown as maximum contaminant levels (MCL) unless otherwise noted as secondary MCLs (SMCL). MCLs are enforceable health-based standards, whereas SMCLs are non-enforceable guidelines for contaminants that may cause aesthetic effects in drinking water.